



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield IL 62703

Facility #	2047018
Date	3/13/2024
Notification Form Received	Y N <input type="radio"/> <input checked="" type="radio"/>

**NOTICE OF VIOLATION (Motor Fuel Dispensing)**

Attended Self-Service

**Facility Status:** Active

**OWNER OF TANKS**

Lenny's Food N Fuel 183rd Street, LLC  
 Name  
8200 185th Street, Suite K  
 Street Address  
Tinley Park IL 60487  
 City State Zip  
Leonard McEnery 708-444-0117  
 Contact Person Phone

**FACILITY**

Lenny's Food N Fuel 183rd Street, LLC  
 Name  
7451 183rd Street  
 Street Address  
Tinley Park IL 60487 Cook  
 City State Zip County  
Len McEnery 708-444-0117  
 Contact Person Phone

Violations of 41 Ill. Adm Code 174, 175, 176 and 177 of the Office of the Illinois State Fire Marshal and 40 CFR Parts 280 of the Federal Register requirements are hereby called to your attention. The violations found and corrections to be made have been identified below or stated in the remarks section. You are allowed a 60-day window to come into compliance effective from the date of this notice. Compliance must be made by **5/12/2024**. Failure to comply may result in refusal to issue, renew, suspend or revoke your motor fuel dispensing permit. Contact the Storage Tank Safety Specialist below when said violations are corrected and if you have any questions.

SECTION A.	EMERGENCY SHUTOFF SWITCHES
SECTION B.	FIRE EXTINGUISHERS
SECTION C.	SIGNS
SECTION D.	DISPENSERS AND HOSES
SECTION E.	FIRE CONTROL AND SUPPRESSION
SECTION F.	FIRE DETECTION SYSTEMS

**SECTION G. MISCELLANEOUS**

Violation Text:  
Farthest dispenser is greater than 40' and site lacks a communication system or system is inoperable

Remarks:  
Dispensers 17/18 and 21-22 communication is not working.

Remarks:  
 \_\_\_\_\_

***(Note: If any equipment fails or is identified as deficient during testing, it must be repaired or replaced to comply with this violation.)***

Signature unobtainable

Signature refused

3/13/2024



X *Christopher A. Lehnert*

Signed by: Christopher A Lehnert

Sherry Wilson

A/B Operator

Storage Tank Safety Specialist (Signature)

Exit interview given to

Title

Phone: 217-900-0465