



Office of the Illinois State Fire Marshal
 Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield IL 62703

Facility #	2047018	
Date	8/27/2025	
Notification Form Received	Y	N
	<input type="radio"/>	<input checked="" type="radio"/>

NOTICE OF VIOLATION (UST)
Facility Status: Active

OWNER OF TANKS

Lenny's Food N Fuel 183rd Street, LLC
 Name
8200 185th Street, Suite K
 Street Address
Tinley Park IL 60487
 City State Zip
Leonard McEnergy 708-444-0117
 Contact Person Phone

FACILITY

Lenny's Food N Fuel 183rd Street, LLC
 Name
7451 183rd Street
 Street Address
Tinley Park IL 60487 Cook
 City State Zip County
Len McEnergy 708-444-0117
 Contact Person Phone

Violations of 41 Ill. Adm Code 174, 175, 176 and 177 of the Office of the Illinois State Fire Marshal and 40 CFR Parts 280 of the Federal Register requirements are hereby called to your attention. The violations found and corrections to be made have been identified below or stated in the remarks section. Any repairs, modifications or alterations to the tank system must be performed in compliance with OSFM rules and by a contractor licensed by this office. You are allowed a 60-day window to come into compliance effective from the date of this notice. If compliance is not made by **10/26/2025**, your underground storage tanks system will be **RED TAGGED AND/OR THE VIOLATION(S) WILL BE REFERRED TO THE ATTORNEY GENERAL'S OFFICE FOR PROSECUTION.** You are prohibited from having product placed into the UST system when a **RED TAG** exists. Contact the Storage Tank Safety Specialist below when said violations are corrected and if you have any questions.

RED TAGS WILL NOT BE REMOVED UNTIL ALL DEFICIENCIES HAVE BEEN CORRECTED.

TANK SYSTEM INFORMATION			
Tank	Capacity	Product	Status
3	12,000	Diesel Fuel	Currently in use

SECTION A. TANK RELEASE DETECTION

SECTION B. PIPING RELEASE DETECTION

Tank ID#

Violation Text:
 Line leak detection equipment in alarm or failed test, must repair or replace.

Remarks:
 Leak detector failed.

SECTION C. SPILL PREVENTION

SECTION D. OVERFILL PREVENTION

SECTION E. TANK CORROSION PROTECTION

SECTION F. PIPING CORROSION PROTECTION

SECTION G. DISPENSERS AND HOSES

SECTION H. MISCELLANEOUS